

## REFLEX FORM - INTERVENTIONS

### Before any intervention:

- ✓ Note the color of the LED and refer to the instructions below.
- ✓ Contact the maintenance team responsible for the protected equipment.
- ✓ Use a thermal camera, as the phenomena detected by E-PREDICT may not be visible to the human eye.
- ✓ Ensure you have the appropriate equipment for working on energized systems.

HDSN disclaims all responsibility if the intervention is not carried out in accordance with applicable legal and safety regulations.

### After each intervention : send an e-mail to [sav@hdsn.fr](mailto:sav@hdsn.fr) with :

- ✓ Serial number of the E-PREDICT (the number is inside the QR code of E-PREDICT)
- ✓ The led color
- ✓ The issue/default

## E-PREDICT - LED STATUS INDICATOR

### IF THE LED IS RED

WHO SHOULD BE NOTIFIED ?

CONTACT (tel/e-mail) :

**WARNING: An electrical fault has been detected.**

An alarm is active. The detected fault may worsen if not addressed.

➔ Get a thermal camera and immediately correct the identified fault.

Once the corrective action is completed, restart E-PREDICT. The LED should return to its normal solid or blinking green state. If the LED remains red, the issue persists and requires further investigation.

### IF THE LED IS OFF

WHO SHOULD BE NOTIFIED ?

CONTACT (tel/e-mail) :

The status LED is off, indicating that **E-PREDICT is not powered.**

➔ **Check the electrical connections and restore power.**

Upon restarting, the LED should return to **solid or blinking green**. If not, the issue persists and further intervention is needed.

### IF THE LED IS ORANGE

WHO SHOULD BE NOTIFIED ?

CONTACT (tel/e-mail) :

Blinking orange: apply the procedure of the TechSpec (fan blocked).

Fixed orange: E-PREDICT is not operational.

- Verify that the **ambient temperature** of the protected equipment does not exceed **70°C**.
- If the issue persists, contact HDSN support at [sav@hdsn.fr](mailto:sav@hdsn.fr), providing the **installation number**.

### IF THE LED IS SOLID OR BLINKING GREEN

E-PREDICT is operating normally. **No action required.**